

## Site Readiness Requirements

A customer's estimated site ready date must meet all the following conditions (completion of the following will ensure prompt installation for your natural gas service):

- The street address must be clearly marked and visible from the road.
- The site must be within 150 mm (6 in.) of final grade and, except in joint trench installation areas, the foundation walls should be backfilled.
- Water, wire and sewer utilities have been installed.
- Service pipe alignment has been staked and entry location has been marked on the foundation wall with an "X" with the word "GAS". (ATCO inside/outside meter setting instructions are available upon request).
- The route to install the service line must be clear of spoil, building materials and other debris.

**Prepayment is due at the time of application; however, additional charges may be incurred during construction.**